

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF MONTGOMERY COUNTY)	
WATER DISTRICT FOR A DEVIATION FROM)	CASE NO.
COMMISSION REGULATIONS REGARDING WATER)	95-406
STORAGE)	

O R D E R

By application received September 14, 1995, Montgomery County Water District ("Montgomery Water") requested permission to deviate from 807 KAR 5:066, Section 4(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Montgomery Water states in its application that its average daily water usage including water sold to the City of Jeffersonville and unaccounted-for water, is approximately 287,859 gallons, and that its current water storage capacity is 200,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Montgomery Water is not in compliance with 807 KAR 5:066, Section 4(4).

2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Montgomery Water should be given until December 31, 2000 to comply with 807 KAR 5:066, Section 4(4).

IT IS THEREFORE ORDERED that:

1. Montgomery Water be and it hereby is given until December 31, 2000 to comply with the provisions of 807 KAR 5:066, Section 4(4).

2. Montgomery Water should take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to December 31, 2000.

Done at Frankfort, Kentucky, this 10th day of October, 1995.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director